


2021 IDDE - Dry Weather Screening

Types of dry weather screening



Method	Date	Screened/flow
Outfall Screening – Overall Creek	8/4/2021	16/0
Outfalls Screening - WFSR	9/15/2021	19/0
Hot Spot	9/27/2021	11/2
Coincidental		/2

Staff observed an increase in building/auto washing during this year’s screening. Targeted education material may be distributed to known washers in a future outreach project.



9/15/2021 -Screening outfalls along West Fork Stones River. City TV filming.



9/29/2021 - Bruce Ross checks for chlorine in flow detected in drainage system at Stones River Mall. Determined to be groundwater. Flow unrelated to wash water.



9/28/2021 - Wash water in drain at Stones River Mall. Flow not leaving property instead infiltrating through joint in pipe. No evidence of washing following day (9/28/21).